



* REFER TO INSTALLATION/OPERATION INSTRUCTIONS AND WIRING DIAGRAM SUPPLIED WITH VENT DAMPER.

REPLACE WIRING WITH 105°C WIRE ONLY AND 150°C AS NOTED.

**WIRING DIAGRAM STG DOE
FIRING MODE-ON/OFF**

BOILER INPUTS: 90,000 BTUH

BOILER SIZE: 90

BOILER TYPE: **H4**

KEY

- 24V
- 120V
- - - 150°C
- - - 120V FIELD WIRE
- WIRE NUT
- BK - BLACK
- BR - BROWN
- BL - BLUE
- R - RED
- O - ORANGE
- Y - YELLOW
- G - GREEN
- V - VIOLET
- W - WHITE
- ⏏ CABINET GROUND
- ⊖ THERMOSTAT

APPROVED BY:

ORIG E.O. 2770

02/02/88

CHG E.O. 2853

08/23/94



152341

1