



SUBMITTAL COVER SHEET

PROJECT NAME _____

LOCATION _____

ARCHITECT _____

ENGINEER _____

CONTRACTOR _____

SUBMITTED BY _____ DATE _____

UNIT SUMMARY

Quantity						
Unit Designation						
Model No.						
Total Cooling						
Sensible Cooling						
Air Ent. Evaporator						
Air Lvg. Evaporator						
Heating Input						
Heating Output						
CFM/ESP						
EER/SEER						
Electrical						
Minimum Ampacity						
Min.-Max. Breaker						
Net Unit Weight						
Accessory						
Catalog Form Number						

ACCESSORIES:

NOTES:

SUBMITTAL SHEET FOR HIGH EFFICIENCY CONDENSING UNITS

(-)APL- JAZ 14 SEER MODELS, 1½-5 TONS [5.27-17.58 kW]

(-)ANL- *AZ 13 SEER MODELS, 1½-5 TONS [5.27-17.58 kW]

JOB NAME _____ UNIT MODEL NO. _____
CONTRACTOR _____ COIL MODEL NO. _____
ENGINEER _____ AIR HANDLER MODEL NO. _____
SUBMITTED FOR ☐ APPROVAL ☐ RECORD LOCATION _____
DATE _____ ORDER NO. _____

UNIT DATA

COOLING PERFORMANCE

EFFICIENCY SEER
TOTAL CAPACITY MBH [kW]
SENSIBLE CAPACITY MBH [kW]
OUTDOOR DESIGN TEMP. °F [°C] DB
TEMP. OF AIR ENTERING
EVAPORATOR COIL °F [°C] DB
..... °F [°C] WB

SUPPLY AIR BLOWER PERFORMANCE

TOTAL AIR SUPPLY CFM [L/s]
TOTAL RESISTANCE EXTERNAL
TO UNIT IWC
MOTOR RATING HP [W]

ELECTRICAL DATA

POWER SUPPLY Hz
MINIMUM WIRE SIZE AWG
MAXIMUM OVERCURRENT DEVICE
FUSES/HACR BREAKER AMPS

CLEARANCES

ACCESS SIDE 24" [609.6 mm]
AIR INLETS 6" [152 mm]
ABOVE UNIT 60" [1524 mm]



FEATURES FOR (-)APL- / (-)ANL- SERIES

- R410-A Refrigerant
- High Efficiency
- Scroll Compressor
- All refrigerant connections are on the exterior of the unit, located close to the ground for neat appearing installations.
- Powder painted galvanized steel cabinet. The full wrap-around louvered grille protects the coil from damage.
- Copper tube—aluminum fin coils are used on all models.
- The control box is located in the top corner of the cabinet providing for easy access through a service panel.
- Service valves are standard on all models.
- Power and control wiring are kept separate.
- Separate compressor compartment for easy service access.
- Drawn, painted base pan for extra corrosion resistance and sound reduction.
- The automatic high and low pressure controls are standard on the (-)APL- JAZ and (-)ANL- *AZ models.
- The filter drier is standard on all models.
- Certified and rated under ARI Standard 210.
- U.L. and cUL listed.
- Factory limited warranty on all parts as follows:

Condenser Coil leaks caused by
factory defects Five (5) Years
Compressor
JAZ Ten (10) Years
CAZ, DAZ, YAZ Five (5) Years
Any Other Part
JAZ Five (5) Years
CAZ, DAZ, YAZ One (1) Year

FIELD INSTALLED ACCESSORIES

Low Ambient Control ☐
Compressor Time Delay Control ☐
Hard Start Components ☐
Compressor Crankcase Heater (CCH) ☐




"Proper sizing and installation of equipment is critical to achieve optimal performance. Split system air conditioners and heat pumps must be matched with appropriate coil components to meet ENERGY STAR criteria. Ask your Contractor for details or visit www.energystar.gov <<http://www.energystar.gov/>>."

DIMENSIONS

Model Number (-)APL-	Height "H" (Inches) [mm]	Length "L" (Inches) [mm]	Width "W" (Inches) [mm]
018/ 024	19 [483]	40 ¹ / ₂ [1029]	27 ⁵ / ₈ [702]
030	29 [737]	44 ³ / ₈ [1127]	31 ¹ / ₂ [800]
036/042/ 048/060	33 [838]	44 ³ / ₈ [1127]	31 ¹ / ₂ [800]

Model Number (-)ANL-	Height "H" (Inches) [mm]	Length "L" (Inches) [mm]	Width "W" (Inches) [mm]
018	19 [483]	35 ¹ / ₂ [902]	23 ³ / ₄ [603]
024/031	19 [483]	40 ¹ / ₂ [1029]	27 ⁵ / ₈ [702]
037/043	23 [584]	44 ³ / ₈ [1127]	31 ¹ / ₂ [800]
049	29 [737]	44 ³ / ₈ [1127]	31 ¹ / ₂ [800]
060	33 [838]	44 ³ / ₈ [1127]	31 ¹ / ₂ [800]

[] Designates Metric Conversions



SPECIAL NOTES ON EQUIPMENT:

Before proceeding with installation, refer to installation instructions packaged with each model, as well as complying with all Federal, State, Provincial, and Local codes, regulations, and practices.

RHEEM
MANUFACTURING
COMPANY
5600 Old Greenwood Road, Fort Smith, Arkansas 72908

"In keeping with its policy of continuous progress and product improvement, Rheem reserves the right to make changes without notice."