



NOTE:

IF ANY OF THE ORIGINAL WIRE AS SUPPLIED WITH THE BOILER MUST BE REPLACED, IT MUST BE REPLACED WITH 105°C WIRE OR ITS EQUIVALENT, AND 150°C AS NOTED.

WIRING DIAGRAM IID

HEATER INPUTS:

HEATER SIZE: **90/135/195**

TYPE: **WH**

KEY	
————	LOW VOLTAGE
-----	FIELD INSTALL
————	LINE VOLTAGE
-----	FIELD INSTALL
BK	BLACK
BL	BLUE
BR	BROWN
GY	GRAY
G	GREEN
R	RED
O	ORANGE
V	VIOLET
W	WHITE
Y	YELLOW

CHECKED BY:
APPROVED BY:
ORIG E.O. 2907 10/14/94
CHG E.O. 5495 2/19/16

