



# South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178  
(909) 396-2000 • www.aqmd.gov

February 12, 2015

Juan Montanez  
Raypak, Inc.  
2151 Eastman Ave.  
Oxnard, CA 93030

Dear Mr. Montanez:

Thank you for your participation in the Rule 1146.2 Administrative Certification Program. As requested by Mr. Bodh Subherwal of BR Labs in his letter dated December 1, 2014, the South Coast Air Quality Management District (SCAQMD) has certified the following natural gas-fired, low-NOx, condensing type boilers as meeting the requirements of Rule 1146.2:

<b>Models</b>	See attached list
Boiler Type per Rule 1146.2	1
Source Test (S/T) conducted by:	B.R. Laboratories, Inc.
S/T Report Date	November 2014
AQMD S/T Nos.	R14461/R14462
NOx Compliance per R1146.2	14 ng/J or 20 ppm @ 3% O <sub>2</sub>

Please note that the SCAQMD does not endorse or warrant any specific product or manufacturer. Modification of the products listed above will void this certification. If you have any questions or require further assistance, please contact Rizaldy Calungcagin at (909) 396-2315 or by e-mail at [rcalungcagin@aqmd.gov](mailto:rcalungcagin@aqmd.gov).

Sincerely,

David De Boer  
Program Supervisor  
Area Sources

cc: File: Raypak



# South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178  
(909) 396-2000 • www.aqmd.gov

## SCAQMD Rule 1146.2 Certification List

### Raypak, Inc.

(Certified @ 14 ng/J or 20 ppm NOx @ 3% O<sub>2</sub>)

Models	Maximum Heat Input Rating (BTU/HR)	Tested	Extended Test Results
H7-088AR-NS	85,000	X	
H7-108AR-NS	110,000		X
H7-198AR-NS	199,000		X
H7-278AR-NS	275,000		X
H7-398A-NS	399,000	X	