



# South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178  
(909) 396-2000 • www.aqmd.gov

July 5, 2012

Mr. Puzant Sherbetjian  
Project Engineer  
Raypak, Inc.  
2151 Eastman Ave.  
Oxnard, CA 93030

Reference: Rule 1146.2 Certification List

Dear Mr. Sherbetjian:

As requested in your letter dated June 8, 2012, the following XFrye Series natural gas-fired hot water boiler and water heater models are certified by extension, and will be reflected in the updated product listing for all certified models.

XFrye Series Models	Heat Input Rating (BTU/HR)
(H7, W7)-300A	300,000
(H7, W7)-400A	399,000
(WH7)-300A	300,000
(WH7)-400A	399,000
(H7, W7)-500A	500,000
(H7, W7)-700A	700,000
(H7, W7)-850A	850,000
(WH7)-500A	500,000
(WH7)-700A	700,000
(WH7)-850A	850,000

The above certifications by extension are approved based on the information you provided that this water heater is identical in design with the currently approved models that meet the 14 ng/J or 20 ppm NOx limit in Rule 1146.2(c)(8).

Please note that the District does not endorse or warrant any specific product or manufacturer. Modification of the products listed will void the certifications. If you have any questions or require further assistance, please contact Rizaldy Calungcagin at (909) 396-2315 or by e-mail at [rcalungcagin@aqmd.gov](mailto:rcalungcagin@aqmd.gov).

Sincerely,

David De Boer  
Program Supervisor  
Area Sources (PRDAS)